



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEx PTB 05.0005X

issue No.:1

Certificate history:

Issue No. 1 (2012-6-25)

Status:

Current

Date of Issue:

2012-06-25

Page 1 of 4

Applicant:

Nass Magnet GmbH
Eckenerstraße 4-6
30179 Hannover
Germany

Electrical Apparatus:
Optional accessory:

Valve solenoid, type 0518 / 1218

Type of Protection:

encapsulation "m", protection by enclosure "t"

Marking:

Ex mb IIC T6, T5, T4

Ex mb tb IIIC T80°C, T95°C, T130°C
IP65

Ex mb IIC T6, T5, T4 Gb

Ex mb tb IIIC T80°C, T95°C, T130°C Db
IP65

Approved for issue on behalf of the IECEx
Certification Body:


Dr.-Ing. Ulrich Johannsmeyer

Position:

Head of Department "Intrinsic Safety and Safety of Systems"

Signature:
(for printed version)

Date:



2012-07-09

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

Physikalisch-Technische Bundesanstalt (PTB)
Bundesallee 100
38116 Braunschweig
Germany





IECEX Certificate of Conformity

Certificate No.: IECEx PTB 05.0005X

Date of Issue: 2012-06-25

Issue No.: 1

Page 2 of 4

Manufacturer: **Nass Magnet GmbH and Precision Controls Kft**
Eckenerstraße 4-6, 30179 Hannover, Germany
Henger utca 2, 8200 Veszprem, Hungary
Germany

Manufacturing location(s):
Nass Magnet GmbH **Precision Controls Kft**
Eckenerstraße 4-6 Henger utca 2
30179 Hannover 8200 Veszprem
Germany Hungary

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2007-10 Edition: 5	Explosive atmospheres - Part 0: Equipment - General requirements
IEC 60079-18 : 2009 Edition: 3	Explosive atmospheres Part 18: Equipment protection by encapsulation "m"
IEC 60079-31 : 2008 Edition: 1	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEX ATR:
DE/PTB/05-006
DE/PTB/ExTR12.0041/00
DE/PTB/QAR08.0002/02

File Reference:
B032086



IECEX Certificate of Conformity

Certificate No.: IECEx PTB 05.0005X

Date of Issue: 2012-06-25

Issue No.: 1

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The valve magnet consists of a solenoid, an armature system and a fixing nut. The armature guide forms the pressure-tight part of the magnet, the guide tube is tested at 1.5 fold the operating pressure. Depending on its design the guide tube is suitable for thread-mounting or flange-mounting. The coil is manufactured of varnished copper wire with insulation class H. This coil is injection-moulded with pre-plastified granules in a mould. A PCB with electronic components is soldered to the terminals of the casted part of the coil. A housing made of glass-fibre-reinforced polyimide is mounted over the terminals and casted.

For electrical data see Attachment.

CONDITIONS OF CERTIFICATION: YES as shown below:

1. A fuse corresponding to its rated current (max. $3 \times I_{rat}$ according IEC 60127-2-1) or a motor protecting switch with short-circuit and thermal instantaneous tripping (set to rated current) shall be connected in series to each solenoid as short circuit protection. For very low rated currents of the solenoid the fuse of lowest current value according to the indicated IEC standard will be sufficient. The fuse may be accommodated in the associated supply unit or shall be separately arranged. The rated voltage of the fuse shall be equal to or higher than the stated rated voltage of the magnet coil. The breaking capacity of the fuse-link shall be as high as or higher than the prospective maximum short circuit current at the location of the installation (usually 1500 A).

2. A maximum permissible ripple of 20 % is valid for all magnets of direct-current design.



IECEX Certificate of Conformity

Certificate No.: IECEx PTB 05.0005X

Date of Issue: 2012-06-25

Issue No.: 1

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

type marking changed



Applicant Nass Magnet GmbH
Electrical Apparatus Solenoid, type 0518.. and 1218..

Electrical data

Type designation	1218..
Type of current	Direct current
Rated voltage	6 V ... 220 V
Rated current	0.845 A ... 0.022 A
Limit power	4.9 W
Max. perm. ambient temperature	40 °C
Temperature class	T6
Medium temperature	70 °C
Single mounting	yes
Butt mounting	no

Type designation	0518..
Type of current	Alternating current
Rated voltage	12 V ... 240 V
Rated current	0.366 A ... 0.021 A
Limit power	4.8 W
Max. perm. ambient temperature	50 °C
Temperature class	T6
Frequency	50 Hz ... 60 Hz
Medium temperature	70 °C
Single mounting	yes
Butt mounting	no

Type designation	1218..
Type of current	Direct current
Rated voltage	6 V ... 220 V
Rated current	0.845 A ... 0.022 A
Limit power	4.6 W
Max. perm. ambient temperature	50 °C
Temperature class	T5
Medium temperature	80 °C
Single mounting	yes
Butt mounting	yes, wall to wall



Type designation	0518..
Type of current	Alternating current
Rated voltage	12 V ... 240 V
Rated current	0.366 A ... 0.021 A
Limit power	4.9 W
Max. perm. ambient temperature	50 °C
Temperature class	T5
Frequency	50 Hz ... 60 Hz
Medium temperature	80 °C
Single mounting	yes
Butt mounting	yes, wall to wall
Type designation	1218..
Type of current	Direct current
Rated voltage	6 V ... 220 V
Rated current	1.58 A ... 0.043 A
Limit power	10.1 W
Max. perm. ambient temperature	50 °C
Temperature class	T4
Medium temperature	80 °C
Single mounting	yes
Butt mounting	yes, wall to wall
Type designation	0518..
Type of current	Alternating current
Rated voltage	12 V ... 240 V
Rated current	0.623 A ... 0.039 A
Limit power	9.2 W
Max. perm. ambient temperature	50 °C
Temperature class	T4
Frequency	50 Hz ... 60 Hz
Medium temperature	80 °C
Single mounting	yes
Butt mounting	yes, wall to wall